

R.I. Analytical Laboratories, Inc.

Laboratory Report

SWSS-Small Water Sys. Services

Work Order #: 1904-07416

Project Name: NEW CARVER ELEMENTARY SCHOOL PB & CU RULE

Sample Number: 001
Sample Description: RM 191
Sample Type : GRAB
Sample Date / Time : 4/24/2019 @ 06:30

PARAMETER	SAMPLE RESULTS	DET. LIMIT	UNITS	METHOD	DATE/TIME ANALYZED	ANALYST
Total Metals Analyzed by ICPMS						
Copper	0.0564	0.0010	mg/l	EPA 200.8	5/2/2019 19:11	AJD
Lead	<0.0010	0.0010	mg/l	EPA 200.8	5/2/2019 19:11	AJD

Sample Number: 002
Sample Description: RM 184
Sample Type : GRAB
Sample Date / Time : 4/24/2019 @ 06:31

PARAMETER	SAMPLE RESULTS	DET. LIMIT	UNITS	METHOD	DATE/TIME ANALYZED	ANALYST
Total Metals Analyzed by ICPMS						
Copper	0.387	0.0010	mg/l	EPA 200.8	5/2/2019 19:15	AJD
Lead	<0.0010	0.0010	mg/l	EPA 200.8	5/2/2019 19:15	AJD

Sample Number: 003
Sample Description: RM 100
Sample Type : GRAB
Sample Date / Time : 4/24/2019 @ 07:03

PARAMETER	SAMPLE RESULTS	DET. LIMIT	UNITS	METHOD	DATE/TIME ANALYZED	ANALYST
Total Metals Analyzed by ICPMS						
Copper	0.197	0.0010	mg/l	EPA 200.8	5/2/2019 20:35	AJD
Lead	<0.0010	0.0010	mg/l	EPA 200.8	5/2/2019 20:35	AJD

R.I. Analytical Laboratories, Inc.

Laboratory Report

SWSS-Small Water Sys. Services

Work Order #: 1904-07416

Project Name: NEW CARVER ELEMENTARY SCHOOL PB & CU RULE

Sample Number: 004
Sample Description: RM 104
Sample Type : GRAB
Sample Date / Time : 4/24/2019 @ 07:04

PARAMETER	SAMPLE RESULTS	DET. LIMIT	UNITS	METHOD	DATE/TIME ANALYZED	ANALYST
Total Metals Analyzed by ICPMS						
Copper	0.381	0.0010	mg/l	EPA 200.8	5/1/2019 19:23	AJD
Lead	<0.0010	0.0010	mg/l	EPA 200.8	5/1/2019 19:23	AJD

Sample Number: 005
Sample Description: RM 112
Sample Type : GRAB
Sample Date / Time : 4/24/2019 @ 07:06

PARAMETER	SAMPLE RESULTS	DET. LIMIT	UNITS	METHOD	DATE/TIME ANALYZED	ANALYST
Total Metals Analyzed by ICPMS						
Copper	0.228	0.0010	mg/l	EPA 200.8	5/1/2019 19:26	AJD
Lead	<0.0010	0.0010	mg/l	EPA 200.8	5/1/2019 19:26	AJD

Sample Number: 006
Sample Description: RM 119
Sample Type : GRAB
Sample Date / Time : 4/24/2019 @ 07:08

PARAMETER	SAMPLE RESULTS	DET. LIMIT	UNITS	METHOD	DATE/TIME ANALYZED	ANALYST
Total Metals Analyzed by ICPMS						
Copper	0.659	0.0010	mg/l	EPA 200.8	5/1/2019 19:27	AJD
Lead	<0.0010	0.0010	mg/l	EPA 200.8	5/1/2019 19:27	AJD

R.I. Analytical Laboratories, Inc.

Laboratory Report

SWSS-Small Water Sys. Services

Work Order #: 1904-07416

Project Name: NEW CARVER ELEMENTARY SCHOOL PB & CU RULE

Sample Number: 007
Sample Description: RM 132
Sample Type : GRAB
Sample Date / Time : 4/24/2019 @ 06:33

PARAMETER	SAMPLE RESULTS	DET. LIMIT	UNITS	METHOD	DATE/TIME ANALYZED	ANALYST
Total Metals Analyzed by ICPMS						
Copper	0.617	0.0010	mg/l	EPA 200.8	5/2/2019 20:47	AJD
Lead	<0.0010	0.0010	mg/l	EPA 200.8	5/2/2019 20:47	AJD

Sample Number: 008
Sample Description: RM 138
Sample Type : GRAB
Sample Date / Time : 4/24/2019 @ 07:10

PARAMETER	SAMPLE RESULTS	DET. LIMIT	UNITS	METHOD	DATE/TIME ANALYZED	ANALYST
Total Metals Analyzed by ICPMS						
Copper	0.822	0.0010	mg/l	EPA 200.8	5/2/2019 19:19	AJD
Lead	<0.0010	0.0010	mg/l	EPA 200.8	5/2/2019 19:19	AJD

Sample Number: 009
Sample Description: RM 241
Sample Type : GRAB
Sample Date / Time : 4/24/2019 @ 07:13

PARAMETER	SAMPLE RESULTS	DET. LIMIT	UNITS	METHOD	DATE/TIME ANALYZED	ANALYST
Total Metals Analyzed by ICPMS						
Copper	0.178	0.0010	mg/l	EPA 200.8	5/2/2019 20:51	AJD
Lead	<0.0010	0.0010	mg/l	EPA 200.8	5/2/2019 20:51	AJD

R.I. Analytical Laboratories, Inc.

Laboratory Report

SWSS-Small Water Sys. Services

Work Order #: 1904-07416

Project Name: NEW CARVER ELEMENTARY SCHOOL PB & CU RULE

Sample Number: 010
Sample Description: RM 238
Sample Type : GRAB
Sample Date / Time : 4/24/2019 @ 07:12

PARAMETER	SAMPLE RESULTS	DET. LIMIT	UNITS	METHOD	DATE/TIME ANALYZED	ANALYST
Total Metals Analyzed by ICPMS						
Copper	0.554	0.0010	mg/l	EPA 200.8	5/2/2019 19:23	AJD
Lead	<0.0010	0.0010	mg/l	EPA 200.8	5/2/2019 19:23	AJD

Sample Number: 011
Sample Description: RM 232
Sample Type : GRAB
Sample Date / Time : 4/24/2019 @ 06:34

PARAMETER	SAMPLE RESULTS	DET. LIMIT	UNITS	METHOD	DATE/TIME ANALYZED	ANALYST
Total Metals Analyzed by ICPMS						
Copper	0.266	0.0010	mg/l	EPA 200.8	5/1/2019 19:28	AJD
Lead	<0.0010	0.0010	mg/l	EPA 200.8	5/1/2019 19:28	AJD

Sample Number: 012
Sample Description: RM 250
Sample Type : GRAB
Sample Date / Time : 4/24/2019 @ 06:35

PARAMETER	SAMPLE RESULTS	DET. LIMIT	UNITS	METHOD	DATE/TIME ANALYZED	ANALYST
Total Metals Analyzed by ICPMS						
Copper	0.362	0.0010	mg/l	EPA 200.8	5/1/2019 19:29	AJD
Lead	<0.0010	0.0010	mg/l	EPA 200.8	5/1/2019 19:29	AJD

R.I. Analytical Laboratories, Inc.**Laboratory Report**

SWSS-Small Water Sys. Services

Work Order #: 1904-07416

Project Name: NEW CARVER ELEMENTARY SCHOOL PB & CU RULE

Sample Number: 013
Sample Description: RM 227
Sample Type : GRAB
Sample Date / Time : 4/24/2019 @ 06:37

PARAMETER	SAMPLE RESULTS	DET. LIMIT	UNITS	METHOD	DATE/TIME ANALYZED	ANALYST
Total Metals Analyzed by ICPMS						
Copper	0.288	0.0010	mg/l	EPA 200.8	5/2/2019 20:56	AJD
Lead	<0.0010	0.0010	mg/l	EPA 200.8	5/2/2019 20:56	AJD

R.I. Analytical Laboratories, Inc.

Laboratory Report

SWSS-Small Water Sys. Services

Work Order #: 1904-07415

Project Name: NEW CARVER ELEMENTARY SCHOOL PB & CU RULE

Sample Number: 001
Sample Description: RM 218
Sample Type : GRAB
Sample Date / Time : 4/24/2019 @ 07:15

PARAMETER	SAMPLE RESULTS	DET. LIMIT	UNITS	METHOD	DATE/TIME ANALYZED	ANALYST
Total Metals Analyzed by ICPMS						
Copper	0.657	0.0010	mg/l	EPA 200.8	5/1/2019 19:35	AJD
Lead	<0.0010	0.0010	mg/l	EPA 200.8	5/1/2019 19:35	AJD

Sample Number: 002
Sample Description: RM 212
Sample Type : GRAB
Sample Date / Time : 4/24/2019 @ 07:16

PARAMETER	SAMPLE RESULTS	DET. LIMIT	UNITS	METHOD	DATE/TIME ANALYZED	ANALYST
Total Metals Analyzed by ICPMS						
Copper	0.675	0.0010	mg/l	EPA 200.8	5/1/2019 19:41	AJD
Lead	<0.0010	0.0010	mg/l	EPA 200.8	5/1/2019 19:41	AJD

Sample Number: 003
Sample Description: RM 211
Sample Type : GRAB
Sample Date / Time : 4/24/2019 @ 06:38

PARAMETER	SAMPLE RESULTS	DET. LIMIT	UNITS	METHOD	DATE/TIME ANALYZED	ANALYST
Total Metals Analyzed by ICPMS						
Copper	0.114	0.0010	mg/l	EPA 200.8	5/1/2019 19:42	AJD
Lead	<0.0010	0.0010	mg/l	EPA 200.8	5/1/2019 19:42	AJD

R.I. Analytical Laboratories, Inc.

Laboratory Report

SWSS-Small Water Sys. Services

Work Order #: 1904-07415

Project Name: NEW CARVER ELEMENTARY SCHOOL PB & CU RULE

Sample Number: 004
Sample Description: RM 263
Sample Type : GRAB
Sample Date / Time : 4/24/2019 @ 06:46

PARAMETER	SAMPLE RESULTS	DET. LIMIT	UNITS	METHOD	DATE/TIME ANALYZED	ANALYST
Total Metals Analyzed by ICPMS						
Copper	0.229	0.0010	mg/l	EPA 200.8	5/1/2019 19:43	AJD
Lead	<0.0010	0.0010	mg/l	EPA 200.8	5/1/2019 19:43	AJD

Sample Number: 005
Sample Description: RM 205
Sample Type : GRAB
Sample Date / Time : 4/24/2019 @ 07:18

PARAMETER	SAMPLE RESULTS	DET. LIMIT	UNITS	METHOD	DATE/TIME ANALYZED	ANALYST
Total Metals Analyzed by ICPMS						
Copper	0.812	0.0010	mg/l	EPA 200.8	5/1/2019 19:44	AJD
Lead	<0.0010	0.0010	mg/l	EPA 200.8	5/1/2019 19:44	AJD

Sample Number: 006
Sample Description: RM 200
Sample Type : GRAB
Sample Date / Time : 4/24/2019 @ 07:19

PARAMETER	SAMPLE RESULTS	DET. LIMIT	UNITS	METHOD	DATE/TIME ANALYZED	ANALYST
Total Metals Analyzed by ICPMS						
Copper	0.912	0.0010	mg/l	EPA 200.8	5/1/2019 19:45	AJD
Lead	<0.0010	0.0010	mg/l	EPA 200.8	5/1/2019 19:45	AJD

R.I. Analytical Laboratories, Inc.**Laboratory Report**

SWSS-Small Water Sys. Services

Work Order #: 1904-07415

Project Name: NEW CARVER ELEMENTARY SCHOOL PB & CU RULE

Sample Number: 007
Sample Description: RM 262
Sample Type : GRAB
Sample Date / Time : 4/24/2019 @ 06:41

PARAMETER	SAMPLE RESULTS	DET. LIMIT	UNITS	METHOD	DATE/TIME ANALYZED		ANALYST
Total Metals Analyzed by ICPMS							
Copper	0.232	0.0010	mg/l	EPA 200.8	5/1/2019	19:47	AJD
Lead	<0.0010	0.0010	mg/l	EPA 200.8	5/1/2019	19:47	AJD